

Evaluation of Electromagnetic Fields from Power Lines in Irrua, Edo State, Nigeria

Abstract

There have been a lot of scientific discords on the effects of electromagnetic fields along electric power lines for close to four decades now. These fields are concentrated close to the power lines and fall with distance. The magnetic fields vary as the load on the power lines changes while the electric fields remain approximately constant. Electric power lines produce large amount of extremely low frequency electromagnetic fields. This research gives an analysis of electromagnetic fields emitted by 330kv electric power lines in Idumebo Community, Irrua, Esan Central Local Government Area of Edo State, Nigeria. The measurements results obtained (using ED78S Electrosmog meter) were compared with the international standard threshold values. The results show that the magnetic field only exceeded the threshold value at the public areas while the electric field at all points is still below the limit as recommended by International Commission of Non-Ionizing Radiation Protection (ICNIRP) and other standard regulatory bodies. We also recommend some practical precautionary measures to extremely low frequency electromagnetic fields.

Keywords: Electromagnetic Fields, Extremely Low Frequency, Threshold Values, Electric Power Lines, Radiation

1.0 Introduction

Electric power transmission lines are considered to be one of the major sources of electromagnetic field which are created by electricity passing through a conductor. The availability of electricity is an essential ingredient in our environment. Provisions of constant electricity improve the standardization of the well-being in a society. The electricity distribution from one region to another depends on network of cables, sited underground and suspended from large metal structures known as pylons. The underground systems are not mostly used in electric power transmission in this part of the world because of some obvious disadvantages, though overhead systems also have its disadvantages [1, 2].

The transmission and distribution stages are very important to Electric power system because without these stages the generated power cannot get to the final consumers [3]. Electricity is generated at power stations and distributed around the country through the High Voltage Electricity Transmission Lines (HVETLs) [4]. The Nigerian transmission network comprises of over 11000km of transmission lines (over 5000km of 330kV transmission lines and 6000km of 132kV transmission lines) among which about 24000km of 33kV sub-transmission lines and 19000km of 11kV distribution lines together with 22500 substations all over the country [5]. Electric power lines at frequency of 50Hz or 60Hz are the prominent source of Electromagnetic Fields of Extremely Low Frequency (ELF) [3]. Electromagnetic Fields (EMFs) and waves are the main media that carry signals and electrons from a certain source to the desired destination. The EMFs are propagating at the speed of light in free space (2.998×10^8 m/s) so it can be modulated, transmitted and received while conveying the necessary information. These electromagnetic waves consist of electric fields perpendicular to the magnetic fields and both are perpendicular to the direction of propagation with the wavelength of the waves depending on the operating frequency [6].

47 2.0 Electromagnetic Radiations

48 Electromagnetic radiations are energies that are propagated through free space in the form of
49 electromagnetic waves. They have properties in common with other forms of waves such as
50 reflection, refraction, diffraction, and interference. However, it may be characterized by the
51 frequency with which it varies over time or by its wavelength. Electromagnetic radiations,
52 however, have particle-like properties in addition to those associated with wave motion.
53 There are many sources of electromagnetic radiations; Natural and Man-made [7]. Based on
54 this research work, electromagnetic radiations can be categorized into two groups:

- 55 • Ionizing Radiation and
- 56 • Non-ionizing Radiation

57 Ionizing radiation holds a great amount of energy to remove electrons and cause the matter to
58 become ionized. Thus, higher frequency waves such as the X-rays and gamma-rays have
59 ionizing radiation. However, lower frequency waves such as radio waves, do not have
60 ionizing radiation and are grouped as non-ionizing ELF EMFs (Non-ionizing radiations)
61 which are produced wherever electricity is generated, distributed or used. There is no doubt
62 that ELF EMFs can have effects on the body if the fields are high enough. Specifically,
63 external EMFs induce internal electric fields in the body tissue, which can interfere with the
64 action of nerves. There is uncertainty as to the exact level of field required to produce these
65 effects, but the threshold for observable induced-field effects on nerves from ELF EMFs is
66 according to most advisory bodies, above **1000 μ T** and 50 kV/m. Electric fields below this
67 level can also produce indirect effects such as micro shocks and contact currents due to
68 surface charge effects as evidence has emerged over the last few decades. The question
69 of whether or not ELF EMFs may cause adverse health effects on humans and his immediate
70 environment has become a source of considerable scientific discord; it should however, be
71 noted that, we are all exposed to different amounts of these fields at different times [2, 8].
72 Magnetic fields can produce electric fields and vice versa. With most types of radiation, the
73 electric and magnetic fields are coupled; they act as one, they are considered together as
74 EMFs. But with ELF radiation, the magnetic field and electrical field can exist and possibly
75 act individually and so they are often and better studied separately [6].

76 A noticeable source of ELF EMFs radiation is the HVETLs which in some instances produce
77 such high losses that they bend the Earth's ionosphere. HVETLs are dangerous because they
78 are constantly losing energy; because we cannot see electricity and we do not use to have a
79 detector so we cannot see it oozing. If we have an ELF spectrum analyser, we could find that
80 ELF EMFs propagate very far, even at long distances and the intensity will be quite
81 significant from biological viewpoint for long term exposures. Even for people living at
82 distance from HVETLs, long term exposure may be dangerous. Often it was found that
83 secondary transmission lines, like in the streets, are much worse polluters than the huge
84 HVETLs. The human body is a living antenna that can absorb and re-emit HVETLs energy in
85 the environment. Animals also could contribute to re-enforcing environment electromagnetic
86 loading. So a school full of children and teachers near HVETLs can become a tremendous
87 new source of electrical energy and a major polluter, not only to the children in the school but
88 even to people living nearby [8]. In the vicinity of transmission lines, the electric field, E and
89 magnetic field, H are typically of the order of a few thousands of volts per metre (V/m) and a
90 few hundreds of milligauss (mG), respectively. It has been confirmed that life is not safe
91 under HVETLs. Apart from the consequence of electric shock that could happen, the
92 magnetic field created around the wire by the flowing current can have adverse biological
93 effects on human like neurological, cardiovascular disorders and low sperm count in the
94 workers who regularly service the line [9, 10] . The influence of electromagnetic radiation on

95 biological matter is called Bio-electromagnetic which occurs when electric current is set up
 96 in tissues of a living organism which may lead to increase in body temperature as a result of
 97 energy deposition (which is the case for people living/working close to HVETLs as their
 98 body is immersed in the fields) causing biological effect. Internal electric and magnetic fields
 99 deposited in living organisms are evaluated using dosimetric calculation; any effect of
 100 electromagnetic energy on a body that is not heat related is referred to as athermal effect.
 101 This can equally result to health hazard. A biological effect is said to have occurred, when
 102 exposure to EMFs cause some significant or detectable physiological change in the biological
 103 system. These effects may occasionally lead to a detrimental health condition. The most
 104 widely accepted standard for Bio-electromagnetic control was developed by the ICNIRP, the
 105 Institution of Electrical and Electronics Engineers (IEEE) and the American National
 106 Standards Institute (ANSI). Protection against adverse health effects require that these basic
 107 restrictions are not exceeded [7, 11-12].

108 The International Radiation Protection Association (IRPA) and ICNIRP recommend that the
 109 electric field and the magnetic field strength should be measured for evaluation of
 110 electromagnetic radiations pollution from HVETLs [8].

111

112 **Tab. 1: Recommended Limits for Electric and Magnetic Fields Strength [13]**

Organization	Public Area		Occupational Area	
	E (V/m)	B(μT)	E(V/m)	B(μT)
ICNIRP	5	0.1	10	0.5
European Union	5	0.1	10	0.5

113

114

115 **3.0 Theoretical Background**

116 Electromagnetic radiations released are related to the temperature of the body. Stephan-
 117 Boltzmann law stated that if this body is a black body; one which perfectly absorbs and emits
 118 radiation, the radiation released is equal to the temperature raised to the fourth power.
 119 Therefore, as temperature increases, the amount of radiation released increases greatly.
 120 Bodies that release radiations will absorb radiations at certain wavelength which is related to
 121 temperature. As the temperature increases, the wavelength of maximum emission decreases.

122 **Electromagnetic radiations which are form of energy emitted and absorbed by a body** that act
 123 as a wave travelling through space are described in terms of its wavelength, frequency, or
 124 energy. All electromagnetic energy travels at the speed of light ($c= 2.998 \times 10^8$ m/s), so
 125 wavelength (λ) and frequency (ν) are inversely related:

126
$$c = \lambda \nu \tag{1}$$

127 The relationship between wavelength and energy, E, is described by the equation:

$$128 \quad E = \frac{hc}{\lambda} \quad (2)$$

129 Where h is Planck's constant ($h = 6.625 \times 10^{-34}$ Js) and c is the speed of light. Replacing the
130 constants h and c with their respective values, Energy E becomes

$$131 \quad E = 1.986 \times 10^{-25} \text{Jm}$$

132 An inverse relationship exists; electromagnetic radiations with shorter wavelengths are more
133 energetic. The relationship between energy and frequency is given by the equation:

$$134 \quad E = h\nu \quad (3)$$

135 A direct relationship exists; electromagnetic radiations with a higher frequency are more
136 energetic, major sources of ELF EMFs are the HVETLs. The lines can produce high losses
137 that might bend the Earth's ionosphere. Interaction of Human body with electric and magnetic
138 fields from HVETL exposure to HVETLs results in internal body currents and energy
139 absorption in tissues as a result of thermo-molecular agitation. This depends on the coupling
140 mechanisms, the frequency (f) and the electrical conductivity of the medium (σ).

141 Radiated coupling occur when electromagnetic energies are emitted from a source which
142 propagates to the far-field and induces voltage and current in another circuit. Unlike common
143 impedance coupling, no conducted path is required. Unlike electric and magnetic field
144 coupling, the victim circuit is not in the electromagnetic near field of the source. Radiated
145 coupling is the only possible coupling mechanism when the source and victim circuits
146 (including all connected conductors) are separated by many wavelengths. Of the four possible
147 coupling mechanisms, radiation coupling is the one that seems to get the most attention. The
148 idea that currents flowing in one circuit can induce currents in another circuit that is across
149 the room or even miles away is fascinating to most of us. Maxwell's treatise on
150 electromagnetism postulated the existence of electromagnetic waves back in 1864. He was
151 able to calculate the velocity of propagation of these waves, and describe wave reflection and
152 diffraction. However, it was twenty five years later before anybody was able to verify the
153 existence of Electromagnetic Waves. Practical transmitters and receivers were not developed
154 until the beginning of the 20th century. People viewed electromagnetic radiation as something
155 nearly magical. The theory was difficult to comprehend and the equipment required to
156 transmit and receive signals was fairly complicated. The more difficult challenge for the
157 designers of most electronic products is to design circuits that do not produce too much
158 electromagnetic radiation. In order to understand how and why circuits exhibit unintentional
159 electromagnetic emissions, it is helpful to review a few general concepts related to
160 electromagnetic radiation [14].

161 **4.0 Materials and Method**

162 To measure the fields from the electric power line sensor ED78S electrosmog meter which
163 detects low frequency (LF) magnetic field in units of tesla or gauss, electric field in unit of
164 V/m and high frequency RF EMF strength signal was used. It also measured LF magnetic
165 field strength which is shown on the digital LCD display (with μT and mG). Two LF modes
166 can be selected;

167 (a) LF30 mode (0.1mG-30mG) and

168 (b) LF 600 mode (1mG – 600G).

169 It runs on an alkaline battery (9volts) and measuring tape to measure distances. The study
 170 areas were selected base on the local HVTPLs distribution. We took measurements (5m,
 171 10m, 15m, 20m, ...100m) of electric and magnetic fields at selected locations along preferred
 172 route. Both electric fields and magnetic fields were measured. Each measurement was
 173 acquired over a short period. Upon stabilization of a reading, the average value was recorded.
 174 Continuous measurements were performed at different distances at each measuring points.
 175 The measurements were taken at a height of 1.5m above sea level. The electric field was
 176 measured in units of V/m and the magnetic field was measured in units of μT . This
 177 instrument meets the Institute of Electrical and Electronic Engineering (IEEE)
 178 instrumentation standard for obtaining valid and accurate field measurements at HVTPLs
 179 frequencies (IEEE Std. 1308 – 1994, R2001, R2010). Measurements of electric field and
 180 magnetic fields were taken horizontally on the preferred Route along a 330kv transmission
 181 line that runs through the power lines at Idumebo area (around Irrua Specialist Teaching
 182 Hospital) Irrua, Edo State, Nigeria.

183

184 5.0 Results and Discussion

185

186 Tabulated results of the measurements are presented in Tab. 2 also in Fig.1


187

188 **Tab.2: Measured values of Electric and Magnetic Fields at 330kV HVETLs in Irrua**

Distance (M)	Mean Electric Field (V/m)	Mean Magnetic Field, B (μT)
5	0.75	0.49
10	0.72	0.47
15	0.67	0.45
20	0.63	0.41
25	0.58	0.37
30	0.55	0.36
35	0.52	0.30
40	0.50	0.28
45	0.48	0.27
50	0.43	0.27
55	0.41	0.21
60	0.40	0.18
65	0.38	0.15
70	0.37	0.12
75	0.35	0.10
80	0.33	0.09

85	0.31	0.07
90	0.30	0.06
95	0.30	0.05
100	0.29	0.05

189
190



191
192
193
194

Fig. 1: Plot of Electric and Magnetic Fields strength at 330kV HVETLs in Irrua

195 Tab. 2 show the measurements from the 330kV HVETLs and Fig.1 show the graphical
196 representation of the electric and magnetic field measurements at distance of 5m to 100m at
197 an interval of 5m around the HVETLs in Idumebo Community Irrua, Edo State, Nigeria. The
198 lowest and highest electric fields measured were 0.29V/m (100m) and 7.5V/m (5m) while
199 that of the magnetic fields were 0.05μT (100m) and 0.49μT (5m) respectively.

200

201 The results show that the magnetic field only exceeded the threshold value at the public area
202 (around Irrua Specialist Teaching Hospital) while the Electric Field at all points; both at the
203 occupational and public areas is still below the limit as recommended by International
204 Commission of Non-Ionizing Radiation Protection (ICNIRP) and other standard regulatory
205 bodies.

206

207 It was also observed that the Right of Way as recommended by Power Holding Company of
208 Nigeria (PHCN), Environmental Standards and Regulations Enforcement Agency (NESREA)
209 and other local and international regulatory bodies both for residential (occupational) and
210 commercial (public) structure were within the recommended limit.

211

212 **6.0 Conclusion and Recommendations**

213

214 The measurement of Electric and Magnetic fields from the 330KV HVETLs at Idumebo
215 Community Community, Irrua, Esan Central L.G.A., Edo State, Nigeria have been carried
216 out using ED78S Electrosnog meter. This was done in other to ascertain and evaluate the

217 amount of electromagnetic radiations from these HVETLs. The obtained results were
218 compared with the international standards and guidelines exposure limits which are set by
219 ICNIRP and other standard regulatory bodies.

220

221 The analytical results shows that the electric field is below the standard threshold limit and do
222 not pose any risk to human health if the exposure is for short period, however, there might be
223 some element of risk if the exposure is for a continuous and long period. The magnetic field
224 results on the other hand, exceeded the standard threshold values at some areas (public areas;
225 Irrua Specialist Teaching Hospital premises) and this of course might constitute a threat to
226 human lives in particular. Scientific knowledge about the health effects of ELF EMFs is
227 based on a large number of technological, epidemiological, animal and environmental
228 studies. Many outcomes have been examined but so far no conclusive evidence or connection
229 has been drawn, further research still need to be done [2, 13, 15].

230 It was also observed from Fig. 1 that where as there were drop in electric field, there were
231 also drop in the magnetic field as the distance increase from the HVETLs simultaneously.
232 Hence, there was a good correlation between electric field and magnetic field and that the
233 Right of Way both for the public and occupational areas was within the recommended limit
234 in the study area.

235

236 Based on the results of the measurement, analysis and evaluation of this research we
237 therefore, make the following recommendations:

238 • Members of the public should be provided with more information about exposures
239 and the mechanism they could take on their own to mitigate exposures to ELF EMFs.

240

241 • Environmental Standards and Regulations Enforcement Agency (NESREA) and other
242 responsible agencies should as a matter of urgency rethink the need for precautionary
243 measures regarding the exposure of people to ELF EMFs.

244

245 • Buildings of any kind either residential or commercial should be stop within
246 specified and recommended distances of power lines.

247

248 • Electricity companies should be encouraged to choose the optimal phasing (usually
249 transposed phasing) for all new power lines and also be encouraged to convert
250 existing power lines where possible and justifiable.

251

252 • Measurement, analysis and evaluation of electromagnetic fields from power lines
253 should be carried out in other parts of the country for risk management and
254 comparative analysis.

255

256 7.0 References

257

258 [1] Bakhshwain, J.M., Shwehdi, M.H., Johar, U.M. and Al-Naim, A.A (2003). Magnetic
259 Fields Measurement and Evaluation of EHV Transmission Lines in Saudi Arabia.
260 *Proceedings of the International Conference on Non-Ionising Radiation at UNITEN,*
261 *Electromagnetic Fields and our Health. pg 1-17.*

262 [2] Ukhurebor Kingsley E, Ushie Patrick O, Ukagwu Kelechi J and Acheme David I (2017).
263 Measurement of Electromagnetic Fields from High Voltage Transmission Power Lines in

- 264 Evbotubu Area of Edo State, Nigeria. *Journal of the Nigeria Association of Mathematical*
265 *Physics, Vol 39 pg 341-346.*
- 266 [3] Aliyu Ozovehe, Maina Ibrahim, Ali Hamdallah (2012). Analysis of Electromagnetic
267 Pollution due to High Voltage Transmission Lines. *Journal of Energy Technologies and*
268 *Policy Vol.2*
- 269 [4] Sandy Bond, Sally Sims and Peter Dent (2013). Towers, Turbines and Transmission
270 Lines: Impacts on Property Value. *First Edition. Blackwell Publishing Ltd.*
271
- 272 [5] Folorunso Oladipo and Olowu Temitayo O (2014). The Nigerian Power System Till Date:
273 A Review. *International Journal of Advance Foundation and Research in Science &*
274 *Engineering (IJAFRSE) Volume 1, Issue 5.*
- 275 [6] A. Mousa (2011). Electromagnetic Radiation Measurements and Safety Issues of some
276 Cellular Base Stations in Nablus. *Journal of Engineering Science and Technology Review 4*
277 *(1) pg 35-42.*
278
- 279 [7] Stakeholder Advisory Group on ELF EMFs (SAGE, 2007). *First Interim Assessment*
- 280 [8] Stakeholder Advisory Group on ELF EMFs (SAGE, 2010). *Second Interim Assessment*
- 281 [9] Aliyu O., Maina I and Ali H (2011). Analysis of Magnetic Field Pollution due to 330kV
282 and 132kV Transmission Lines. *Journal of Technology and Educational Research Vol. 4, No.*
283 *2, pp. 87-93.*
- 284 [10] Siaka M (2010). Highlighting the dangers of living under high tension cables.
285 *Businessday Newspaper. Thursday 01 July, 2010.*
286
- 287 [11] World Health Organization (WHO, 2007). *Standards and Guidelines Electromagnetic*
288 *Fields (EMFs).*
- 289 [12] Aliyu .O, Adekola S. A. and Ade O (2009). Practical Assessment of Exposure Levels
290 due to Radiations from GSM Base Stations. *International Conference on Power*
291 *Telecommunication, Abuja, Nigeria.*
- 292 [13] ICNIRP Guideline (1998). Guidelines for Limiting Exposure to time-varying Electric,
293 Magnetic and Electromagnetic Fields (up to 300GHz). *Health Physics Vol. 74 pg 17-18.*
- 294 [14] Joseph A. Edminister (1995). Electromagnetism, Second Edition. *Mcgraw Hill. ISBN 0-*
295 *07-018993-5.*
- 296 [15] Awn B. Rifai and Majed A. Hakami (2014). Health Hazards of Electromagnetic
297 Radiation. *Journal of Biosciences and Medicines Vol 2, pg 1-12*